

# MIMO PID Tuning via Iterated LMI Restriction

S. Boyd      M. Hast      K. J. Åström

Originally posted July 2014. Updated version February 2015.

## Abstract

We formulate multi-input multi-output (MIMO) proportional-integral-derivative (PID) controller design as an optimization problem that involves nonconvex quadratic matrix inequalities. We propose a simple method that replaces the nonconvex matrix inequalities with a linear matrix inequality (LMI) restriction, and iterates to convergence. This method can be interpreted as a matrix extension of the convex-concave procedure, or as a particular majorization-minimization (MM) method. Convergence to a local minimum can be guaranteed. While we do not know that the resulting controller is globally optimal, the method works well in practice, and provides a simple automated method for tuning MIMO PID controllers. The method is readily extended in many ways, for example to the design of more complex, structured controllers.

## 1 Introduction

Single-input single-output (SISO) proportional-integral-derivative (PID) control is the automatic control scheme most widely used in practice, with a long history going back at least 250 years; see [ÅH06, §1.4]. It has only three parameters to tune, and achieves reasonable or good performance on a wide variety of plants. The effect of the tuning parameters (or gains) on the closed-loop performance are well understood, and there are well known simple rules for tuning these parameters; see, *e.g.*, [ÅH06, Chap. 6] or [Luy86]. Systems for automatically tuning SISO PID controllers have been developed, and are available in commercial controllers [ÅH06, GH08, GHÅ12, VV12]. The authors of this paper recently developed yet another SISO PID tuning method in [HÅBB13], which is a precursor for the method described in this paper.

SISO PID controllers have been used for multiple-input multiple-output (MIMO) plants for many years. This is generally done by pairing inputs (actuators) and outputs (sensors), and connecting them with SISO PID controllers. These SISO PID controllers can be tuned one at a time (in ‘successive loop closure’) using standard SISO PID tuning rules. For MIMO plants that are already reasonably well decoupled, multi-loop SISO PID design can work well. Unlike SISO PID design, however, MIMO PID design is more complex; the SISO loops have to be chosen carefully, and then tuned the correct way in the correct order.

An alternative to multi-loop SISO PID control is to design one MIMO PID controller, which uses matrix coefficients, all at once. Such a controller potentially uses all sensors to drive all actuators, but it is possible to specify a simpler structure by imposing a sparsity constraint on the controller gain matrices. Like SISO PID controllers for SISO plants, MIMO PID controllers can achieve very good performance on a wide variety of MIMO plants, even when the plant dynamics are quite coupled. The challenge is in tuning MIMO PID controllers, which require the specification of three matrices, each with a number of entries equal to the number of plant inputs times the number of plant outputs. For example, a MIMO PID controller for a plant with 4 inputs and 4 outputs requires the specification of up to 48 parameters. This would be very difficult, if not impossible, to tune by hand one parameter at a time. Hand tuning a MIMO PID controller with 10 inputs and 10 outputs would be impossible in practice.

In this paper we describe a method for designing MIMO PID controllers. The method is based on solving a small number of convex optimization problems, specifically semidefinite programs (SDPs), which can be done efficiently. Our method is a local optimization method, and we cannot guarantee that it finds the globally optimal controller parameter values. On many examples, however, the method seems to work very well.

We first describe a basic form for the method. We impose constraints on the sensitivity and complementary sensitivity transfer functions, which guarantees closed-loop stability and a MIMO stability margin, and also a limit on actuator effort. The objective is to minimize the low-frequency sensitivity of the closed-loop system, which is a MIMO analog of maximizing the integral gain in the SISO case. In a later section we describe a number of generalizations of the method.

There is an enormous literature on automated SISO PID tuning, and a very large literature on MIMO PID tuning (see, *e.g.*, [ÅPH98] and its references, or [PÅH02, SKW07]) including some methods that are very close to the one we describe, and others that are close in spirit. We give a more detailed technical analysis of other methods in §6.4, after describing the details of our method. But we mention here some earlier work that is very closely related to ours. In [LWL04], the authors also form a linear matrix inequality (LMI) based restriction of a problem with nonconvex quadratic matrix inequalities, and iterates to convergence. Another previous work that is close in spirit to ours is [BMC08], which formulates the design problem as one involving bilinear matrix inequalities (BMIs), which are in turn solved (approximately) by iteratively solving a set of SDPs. (The connection between our method and BMI formulations will be discussed in §6.4.) The closest prior work appears in [SOW10], which takes a very similar approach to ours. The authors consider MIMO PID design, using frequency-domain specifications, and their algorithm involves LMI restrictions of nonconvex matrix inequalities, as our method does. We will discuss some of the differences in §6.4.

## 2 Model and assumptions

### 2.1 Plant

The linear time-invariant plant has  $m$  inputs (actuators) and  $p$  outputs (sensors), and is given by its transfer function  $P(s) \in \mathbf{C}^{p \times m}$ , or more specifically by its frequency response  $P(i\omega)$ , for  $\omega \in \mathbf{R}_+$ . We do not assume that  $P$  is rational; it can, for example, include transport delay. We assume that the entries of the plant input  $u(t) \in \mathbf{R}^m$  are measured in appropriate units (or scaled), so their sizes are (roughly) the same order. We make the same assumption about the plant output  $y(t) \in \mathbf{R}^p$ . These assumptions justify the use of the (unweighted)  $\ell_2$ -norm to measure the actuator effort and deviation of the plant outputs from the reference signal, and more generally, it justifies the use of (unweighted) matrix norms to measure closed-loop gains.

We make several assumptions about the plant. We assume that  $p \leq m$ , *i.e.*, there are at least as many actuators as plant outputs, and that  $P(0)$  is full rank. This makes it possible to achieve perfect reference tracking at DC ( $s = 0$ ). We will also assume that the plant is stable and strictly proper, *i.e.*,  $P(s) \rightarrow 0$  as  $s \rightarrow \infty$ . Most of our assumptions can be relaxed or extended to more general settings, but our goal is to keep the ideas simple for now. We will discuss various ways these assumptions can be relaxed in §7.

### 2.2 PID controller

The controller is a proportional-integral-derivative (PID) controller, given by

$$C(s) = K_P + \frac{1}{s}K_I + \frac{s}{1 + \tau s}K_D,$$

where  $K_P, K_I, K_D \in \mathbf{R}^{m \times p}$  are the *proportional gain matrix*, *integral gain matrix*, and *derivative gain matrix*, respectively. The  $3mp$  entries in these matrices are the design parameters we are to choose. The constant  $\tau > 0$  is the derivative action time constant, and is assumed to be fixed and responsibly chosen, for example, a modest fraction of the desired closed-loop response time.

The plant and controller are connected in the classical loop shown in figure 1, described by the equations

$$e = r - y, \quad u = Ce, \quad y = P(u + d),$$

where  $r$  is the reference input,  $e$  is the error, and  $d$  is an input-referred plant disturbance. The signals  $u$  and  $y$  are the plant input and output, respectively.

### 2.3 Closed-loop transfer functions

We will be interested in several closed-loop transfer functions that we describe here.




Figure 1: Classical feedback interconnection.

**Sensitivity.** The transfer function from reference input  $r$  to error  $e$  is the *sensitivity*  $S = (I + PC)^{-1}$ . The size of  $S$  gives a measure of the tracking error; for low frequencies  $S$  should be small. When  $S(0) = 0$  (a constraint we will impose), we have perfect static tracking. The maximum size of  $S$ , which occurs near the crossover frequency, is closely related to closed-loop damping and system stability.

**$Q$ -parameter.** The transfer function from  $r$  to  $u$  is denoted  $Q$ , defined as  $Q = C(I + PC)^{-1}$ . Its size is a measure of the actuator effort. (We use  $Q$  to match the notation often used in Youla's parametrization of closed-loop transfer functions; see [BB91].)

**Complementary sensitivity function.** The *complementary sensitivity function* is  $T = PC(I + PC)^{-1}$ . It is the closed-loop transfer function from  $r$  to  $y$ . It is near the identity for low frequencies, and will be small for high frequencies; its maximum size is also related to closed-loop damping.

These three closed-loop transfer functions are sufficient to guarantee a sensible controller design (since  $P$  is assumed stable). They are related in various ways; for example, we have

$$S + T = I, \quad T = PQ, \quad Q = CS.$$

**Other closed-loop transfer functions.** Several other closed-loop transfer functions can also be considered. For example, the closed-loop transfer function from the plant disturbance  $d$  to the tracking error  $e$  is  $R = -(I + PC)^{-1}P$ . It will be clear how our approach extends to other transfer functions.

## 2.4 Notation

For a complex matrix  $Z \in \mathbf{C}^{p \times q}$ ,  $Z^*$  is its (Hermitian) conjugate transpose,  $\|Z\|$  denotes the spectral norm, *i.e.*, the maximum singular value. For full rank  $Z$ , we let  $\sigma_{\min}(Z)$  denote its minimum singular value. A square matrix is Hermitian if  $Z = Z^*$ . Between Hermitian matrices the symbol  $\succeq 0$  is used to denote matrix inequality, so  $Z \succeq 0$  means that  $Z$  is Hermitian and positive semidefinite. We use the notation  $Z^{-*} = (Z^*)^{-1}$ .

For a  $p \times q$  transfer function  $H$ ,  $\|H\|_{\infty}$  is its  $\mathbf{H}_{\infty}$ -norm,  $\|H\|_{\infty} = \sup_{\Re s \geq 0} \|H(s)\|$ , which can be expressed as

$$\|H\|_{\infty} = \sup_{\omega \geq 0} \|H(i\omega)\|$$

when  $H$  is stable (*i.e.*,  $H \in \mathbf{H}_\infty^{p \times q}$ ).

### 3 Design problem

#### 3.1 Objective and constraints

**Sensitivity and complementary sensitivity peaking.** We require  $\|S\|_\infty \leq S_{\max}$ , where  $S_{\max} > 1$ . Reasonable values of  $S_{\max}$  are in the range 1.1 to 1.6; lower values give a more damped closed-loop system. This constraint ensures closed-loop stability. We also require  $\|T\|_\infty \leq T_{\max}$ , with  $T_{\max} > 1$ . Reasonable values of  $T_{\max}$  are similar to those for  $S_{\max}$ .

**Static and low frequency sensitivity.** Assuming that  $P(0)K_I$  is nonsingular, we have  $S(0) = 0$ , which means that we have zero error for constant reference signals. The next term in the expansion of the sensitivity near  $s = 0$  is  $S(s) \approx s(P(0)K_I)^{-1}$  for  $|s|$  small. Our objective will be to attain the best possible low-frequency sensitivity, which means we will minimize  $\|(P(0)K_I)^{-1}\|$ . This objective indirectly imposes the condition that we achieve perfect tracking since when it is finite we have  $P(0)K_I$  nonsingular.

**Actuator authority limit.** We require that  $\|Q\|_\infty \leq Q_{\max}$ . This sets a maximum value for the size of the closed-loop actuator signal in response to the reference signal. Since the plant is stable, this constraint ensures that the closed-loop system is stable; see [BB91].

We can determine a reasonable value for  $Q_{\max}$  as follows. Any controller that has a finite objective value (*i.e.*, achieves perfect reference tracking at  $s = 0$ ) satisfies  $T(0) = I = P(0)Q(0)$ ; this has the simple interpretation that at  $s = 0$ , the controller inverts the plant. It follows that  $\|Q(0)\| \geq 1/\sigma_{\min}(P(0))$ , from which we conclude  $\|Q\|_\infty \geq 1/\sigma_{\min}(P(0))$ . Thus we must have  $Q_{\max} \geq 1/\sigma_{\min}(P(0))$ . The righthand side can be interpreted as the minimum actuator effort (measured by  $\|Q\|_\infty$ ) required to achieve static tracking. A reasonable value for  $Q_{\max}$  is therefore a modest multiple of  $1/\sigma_{\min}(P(0))$ , say, three to ten.

**Design problem.** Putting it all together we obtain the problem

$$\begin{aligned} & \text{minimize} && \|(P(0)K_I)^{-1}\| \\ & \text{subject to} && \|S\|_\infty \leq S_{\max}, \\ & && \|T\|_\infty \leq T_{\max}, \\ & && \|Q\|_\infty \leq Q_{\max}. \end{aligned} \tag{1}$$

The variables to be chosen are the coefficient matrices  $K_P, K_I, K_D$ ; the problem data are the plant transfer function  $P$ , the controller derivative time constant  $\tau$ , and the design parameters  $S_{\max}, T_{\max}$ , and  $Q_{\max}$ . This problem is not convex. Note that the objective contains the implied constraint that  $P(0)K_I$  is invertible, which implies that perfect static tracking is achieved for constant reference inputs.

### 3.2 Sampling semi-infinite constraints

The constraints on the closed-loop transfer functions can be expressed as, for example,

$$\|S(i\omega)\| \leq S_{\max}, \quad \forall \omega \geq 0.$$

This is a so-called semi-infinite constraint, since it consists of an infinite number of constraints, one for each  $\omega \geq 0$ . Semi-infinite constraints such as these (with one parameter,  $\omega$ ) are readily handled by choosing a reasonable finite (but large) set of frequency samples  $0 < \omega_1 < \dots < \omega_N$ , and replacing the semi-infinite constraints with the finite set of constraints at each of the given frequencies. For example, we replace the constraint  $\|S\|_\infty \leq S_{\max}$  with  $\|S(i\omega_k)\| \leq S_{\max}$ ,  $k = 1, \dots, N$ . Our optimization method has a computational complexity that grows linearly with  $N$ , so we can choose a large enough value of  $N$  (say, several hundred or more) that this sampling has no practical effect. By ‘reasonable’ we mean that the frequency sampling is fine enough to catch any rapid changes in the closed-loop transfer function with frequency, and also cover an appropriate range; in particular, we assume that at  $\omega_1$  and  $\omega_N$  the transfer functions are near their asymptotic values,

$$S(0) = 0, \quad T(0) = I, \quad Q(0) = K_I(P(0)K_I)^{-1},$$

and

$$S(\infty) = I, \quad T(\infty) = 0, \quad Q(\infty) = K_P + (1/\tau)K_D,$$

respectively.

We will use subscripts to denote a transfer function evaluated at the frequency  $s = i\omega_k$ . For example,  $P_k = P(i\omega_k)$ , which is a (given) complex matrix. Note that the quantity  $C_k = C(i\omega_k)$  is a complex matrix, and is an affine function of the design variables  $K_P, K_I, K_D$ .

The sampled problem is then

$$\begin{aligned} & \text{minimize} && \|(P(0)K_I)^{-1}\| \\ & \text{subject to} && \|S_k\| \leq S_{\max}, \\ & && \|T_k\| \leq T_{\max}, \\ & && \|Q_k\| \leq Q_{\max}, \\ & && k = 1, \dots, N. \end{aligned} \tag{2}$$

This problem has  $3N$  constraints, each of which has the form of a matrix norm inequality. The arguments of the matrix norm inequalities, however, are complex functions of the design variables  $K_P, K_I, K_D$ , given by the various formulas for the closed-loop transfer functions.

## 4 Quadratic matrix inequality form

In this section we show how the (frequency sampled) design problem (2) can be cast in a simple form in which every constraint has the same *quadratic matrix inequality* (QMI) form

$$Z^*Z \succeq Y^*Y, \tag{3}$$

where both  $Z$  and  $Y$  are affine functions of the variables.

We start with the objective. First we note that we can just as well maximize  $\sigma_{\min}(P(0)K_I) = 1/\|(P(0)K_I)^{-1}\|$ . We introduce a new scalar variable  $t$ , which we maximize subject to  $\sigma_{\min}(P(0)K_I) \geq t$ . (This is the standard epigraph transformation; see [BV04, §4.2.4].) We then observe that

$$\sigma_{\min}(P(0)K_I) \geq t \Leftrightarrow (P(0)K_I)^*(P(0)K_I) \succeq t^2 I,$$

which has the form (3) with  $Z = P(0)K_I$  and  $Y = tI$ , both of which are affine functions of the variables.

Now consider the sensitivity peaking limit  $\|S_k\| \leq S_{\max}$ . As above, we have

$$\begin{aligned} \|S_k\| \leq S_{\max} &\Leftrightarrow (I + P_k C_k)^{-*} (I + P_k C_k)^{-1} \preceq S_{\max}^2 I \\ &\Leftrightarrow (I + P_k C_k)^* (I + P_k C_k) \succeq (1/S_{\max}^2) I, \end{aligned}$$

where in the second line we have multiplied the left and right sides by  $(I + P_k C_k)^*$  and by  $(I + P_k C_k)$ , respectively. This has the QMI form (3) with  $Z = I + P_k C_k$  and  $Y = (1/S_{\max}^2)I$ .

For the complementary sensitivity constraint  $\|T_k\| \leq T_{\max}$ , we have

$$\begin{aligned} \|T_k\| \leq T_{\max} &\Leftrightarrow (I + P_k^* C_k^*)^{-1} C_k^* P_k^* P_k C (I + P_k C_k)^{-1} \preceq T_{\max}^2 I \\ &\Leftrightarrow (I + P_k C_k)^* (I + P_k C_k) \succeq (1/T_{\max}^2) (P_k C_k)^* (P_k C_k). \end{aligned}$$

This has the QMI form (3) with  $Z = I + P_k C_k$  and  $Y = (1/T_{\max}^2) P_k C_k$ .

In a similar way we have

$$\|Q_k\| \leq Q_{\max} \Leftrightarrow (I + P_k C_k)^* (I + P_k C_k) \succeq (1/Q_{\max}^2) C_k^* C_k,$$

which has QMI form with  $Z = I + P_k C_k$  and  $Y = (1/Q_{\max}^2) C_k$ .

We arrive at a problem with the form

$$\begin{aligned} &\text{maximize } t \\ &\text{subject to } Z_k^* Z_k \succeq Y_k^* Y_k, \quad k = 1, \dots, M, \end{aligned} \tag{4}$$

with variables  $t, K_P, K_I, K_D$ . (Here we have  $M = 3N + 1$ .) This is the PID controller design problem in QMI form.

## 5 Linear matrix inequality restriction

We first show how to form a (convex) *linear matrix inequality* (LMI) restriction for the QMI  $Z^* Z \succeq Y^* Y$ . (See [BGFB94] for background on matrix inequalities.) The QMI is already convex in  $Y$ , so we can focus on  $Z$ . We start with the simple matrix inequality

$$0 \preceq (Z - \tilde{Z})^* (Z - \tilde{Z}) = Z^* Z - Z^* \tilde{Z} - \tilde{Z}^* Z + \tilde{Z}^* \tilde{Z},$$

valid for any matrices  $Z$  and  $\tilde{Z}$ . Re-arranging we get

$$Z^* Z \succeq Z^* \tilde{Z} + \tilde{Z}^* Z - \tilde{Z}^* \tilde{Z}.$$




Figure 2: LMI restriction (shown in red) of QMI (shown in blue) for simple case when  $Z$  and  $Y$  are scalar and real.

The lefthand side is a quadratic function of  $Z$ ; the righthand side is an affine function of  $Z$ . It follows that the matrix inequality

$$Z^* \tilde{Z} + \tilde{Z}^* Z - \tilde{Z}^* \tilde{Z} \succeq Y^* Y,$$

which is convex in  $(Z, Y)$ , implies  $Z^* Z \succeq Y^* Y$ ; that is, it is a convex restriction of the QMI. We can write this convex quadratic matrix inequality as an LMI

$$\begin{bmatrix} Z^* \tilde{Z} + \tilde{Z}^* Z - \tilde{Z}^* \tilde{Z} & Y^* \\ Y & I \end{bmatrix} \succeq 0. \quad (5)$$

(Here  $Z$  and  $Y$  are the variables;  $\tilde{Z}$  is an arbitrary matrix.) For any matrix  $\tilde{Z}$ , the LMI (5) implies the QMI  $Z^* Z \succeq Y^* Y$ . We call it the *LMI restriction* of the QMI, obtained at the point  $\tilde{Z}$ .

The LMI restriction of the QMI is illustrated in figure 2, for the simple case of real scalar  $Z$  and  $Y$ . In this case the QMI is  $z^2 \geq y^2$ , which gives the two lightly shaded cones in the figure, with blue boundary. The LMI restriction at  $\tilde{z}$  is given by  $2\tilde{z}z - \tilde{z}^2 \geq y^2$ , shown as the shaded region bounded by the parabola, with red boundary. The two boundaries touch at the point where  $z = \tilde{z}$ .

Now consider the QMI form PID controller design problem (4). Given any matrices  $\tilde{Z}_1, \dots, \tilde{Z}_M$ , we can form the *LMI restricted problem*

$$\begin{aligned} & \text{maximize} && t \\ & \text{subject to} && \begin{bmatrix} Z_k^* \tilde{Z}_k + \tilde{Z}_k^* Z_k - \tilde{Z}_k^* \tilde{Z}_k & Y_k^* \\ Y_k & I \end{bmatrix} \succeq 0, \quad k = 1, \dots, M. \end{aligned} \quad (6)$$

This problem has linear objective and LMI constraints, and so is a semidefinite program (SDP) [VB96]. It is readily solved (globally). Note that any solution of the LMI restriction



is feasible for the QMI problem. The LMI restriction, however, need not be feasible; this depends on the choice of  $\tilde{Z}_k$ .

**Simplifications.** In the inequalities associated with  $S_k$ , the matrix  $Y_k$  does not depend on the controller parameters (*i.e.*, is constant). In this case we can work directly with the smaller (equivalent) LMIs

$$Z_k^* \tilde{Z}_k + \tilde{Z}_k^* Z_k - \tilde{Z}_k^* \tilde{Z}_k \succeq Y_k^* Y_k,$$

which can give a modest computational advantage.

Another simplification is to maximize the variable  $w = t^2$ ; in this case the single inequality associated with the objective can be handled as the smaller LMI

$$Z_1^* \tilde{Z}_1 + \tilde{Z}_1^* Z_1 - \tilde{Z}_1^* \tilde{Z}_1 \succeq wI,$$

where  $Z_1 = P(0)K_I$ . This simplification leads to slightly faster convergence, since  $t$  is only an upper bound on  $\|(P(0)K_I)^{-1}\|$ , whereas  $w^{-1/2}$  is actually equal to the objective, after optimization.

## 6 The method

### 6.1 Controller initialization

We first initialize the controller with

$$K_P = 0, \quad K_I = \epsilon P(0)^\dagger, \quad K_D = 0,$$

where  $\epsilon$  is small and positive, and  $P(0)^\dagger = P(0)^T (P(0)P(0)^T)^{-1}$  is the pseudo-inverse of the DC gain. For small enough  $\epsilon$ , this controller is feasible. Indeed, as  $\epsilon \rightarrow 0$ , we have

$$S(s) \rightarrow \frac{s}{\epsilon + s} I, \quad T(s) \rightarrow \frac{\epsilon}{\epsilon + s} I, \quad Q(s) \rightarrow \frac{\epsilon}{\epsilon + s} P(0)^\dagger,$$

from which it follows that the constraints  $\|S\|_\infty \leq S_{\max}$ ,  $\|T\|_\infty \leq T_{\max}$ , and  $\|Q\|_\infty \leq Q_{\max}$  are feasible for small enough  $\epsilon$  (assuming  $S_{\max} > 1$ ,  $T_{\max} > 1$ , and  $Q_{\max} > 1/\sigma_{\min}(P(0))$ ). Note that  $\|Q\|_\infty$  finite implies closed-loop stability of this initial controller.

### 6.2 Iteration

We then repeat the following steps. We form the LMI restriction (6), using  $\tilde{Z}_k = Z_k^{\text{curr}}$ , where  $Z_k^{\text{curr}}$  is the current value of  $Z_k$ . This choice guarantees the LMI restriction is feasible. We solve this SDP to get the updated values of the design variables. These are feasible, since they were constrained by the restrictions, and the objective  $t$  (which is an upper bound on the original objective  $\|(P(0)K_I)^{-1}\|$ ) cannot decrease.

### 6.3 Convergence

The iterates are all feasible (and we have closed-loop stability since  $\|Q\|_\infty$  is finite), and the objective is nonincreasing. Since it is nonnegative, the objective converges. We can stop when not much progress is being made, which is typically after ten or fewer iterations. At convergence, the optimal value of  $t$ , which is in general an *upper bound* on the original objective  $\|(P(0)K_I)^{-1}\|$ , is actually *equal* to this value. (When we optimize with the variable  $w$ , it is directly equal to the objective.)

### 6.4 Connections, interpretations, and prior work

Our method is similar to, but not the same as, the convex-concave method for the SISO case described in [HÅBB13]. In that paper we linearize a scalar inequality of the form  $|Z| \geq |Y|$ , which is not the same as linearizing (as we do here) the quadratic inequality  $|Z|^2 \geq |Y|^2$ . The idea of linearizing concave terms in an otherwise convex optimization problem, which gives a convex restriction, is an old one that has been (re-)invented many times, for many applications; see, *e.g.*, the references in [LB14] or [YR03]. The idea of linearizing a matrix inequality is given in [LB14].

The convex-concave procedure is in turn a special case of a very general method for finding a local minimum of a nonconvex optimization problem. In each iteration we replace the objective function and each constraint function by a convex majorization that is tight at the given point, and solve the resulting convex problem. This idea traces back at least to 1970 [OR70], and has been widely used since then; see [LB14].

There is also a very close connection of our method to BMIs and methods for them, such as alternating minimization over the two groups of variables. The connection is easiest to see and state when  $Z$  and  $Y$  have the same dimensions (in general the inequality  $Z^*Z \succeq Y^*Y$  implies they have the same number of columns). Define

$$U = (1/2)(Z + Y), \quad V = (1/2)(Z - Y),$$

so  $Z = U + V$  and  $Y = U - V$ . Then we have

$$\begin{aligned} Z^*Z \succeq Y^*Y &\Leftrightarrow (U + V)^*(U + V) \succeq (U - V)^*(U - V) \\ &\Leftrightarrow U^*U + V^*U + U^*V + V^*V \succeq U^*U - V^*U - U^*V + V^*V \\ &\Leftrightarrow V^*U + U^*V \succeq 0, \end{aligned}$$

which we recognize as a BMI in  $U$  and  $V$ . Thus our quadratic matrix inequality can be expressed as an equivalent BMI. MIMO PID design via BMIs is discussed in [BMC08].

The closest prior work is [SOW10], which contains many of the ideas we use in the present paper. The authors develop quadratic matrix inequalities similar to the ones we use here, and derive a method for MIMO PID design that uses LMI restrictions, as we do. While the two methods are clearly closely related, we are unable to derive our exact algorithm from theirs. We can identify several differences in the approach. First, we consider separate closed-loop

transfer functions (*e.g.*,  $S$ ,  $T$ ,  $Q$ ), where they lump them together into one block closed-loop transfer function. One advantage of considering these closed-loop transfer functions separately is that we can give simple and universal choices for the upper bound (such as 1.4, for example, for  $S$ ). Second, we consider stable plants, which allows us to give a simple low gain PID initialization. Finally, we consider a generic quadratic matrix inequality, and develop a simple universal LMI restriction.

## 7 Extensions and variations

In this section we list various extensions and variations on the MIMO PID controller design problem, starting with simple ones and moving to more complex ones. While the basic iteration will work in all of these variations, the design must start from a feasible initial controller, which may be a challenge to find, depending on the variation. (We make more specific comments about this below.)

**Exchanging objectives and constraints.** As always, we can exchange constraints and objective; for example, we could impose a constraint on  $\|(P(0)K_I)^{-1}\|$ , and instead minimize another objective, such as  $\|Q\|_\infty$ . In this example, we would be minimizing actuator effort for a given fixed limit on the low-frequency sensitivity.

**Frequency-dependent bounds.** The bounds  $S_{\max}$ ,  $T_{\max}$ ,  $Q_{\max}$  could be functions of frequency. This could be used to shape the various closed-loop transfer functions in more sophisticated ways than described here.

**Other closed-loop transfer functions.** The same approach works for other closed-loop transfer functions. For example, consider  $R = -(I + PC)^{-1}P$ , which is the closed-loop transfer function from disturbance to error. A limit on  $R$ , say,  $\|R\|_\infty \leq R_{\max}$ , can be expressed as a QMI as follows:

$$\|R_k\| \leq R_{\max} \Leftrightarrow (I + P_k C_k)(I + P_k C_k)^* \succeq (1/R_{\max}^2)P_k P_k^*,$$

which has QMI form with  $Z = (I + P_k C_k)^*$  and  $Y = (1/R_{\max})P_k^*$ . (Note the Hermitian conjugates in this case.)

**Low frequency disturbance optimization.** We can optimize low-frequency values of  $R$  instead of  $S$ . At low frequencies we have

$$R(s) = -S(s)P(s) \approx -s(P(0)K_I)^{-1}P(0),$$

and we arrive at a very similar problem, which is also easily expressed in our QMI form.

**High frequency roll-off.** Our method relies only on the fact that  $C(s)$  is a linear function of the design variables  $K_P, K_I, K_D$ . This allows us to use many other variations on the PID controller. As an example of simple variation that is very useful in practice, we can use the controller

$$C(s) = \left( \frac{1}{1 + s\tau + (s\tau)^2/2} \right) \left( K_P + \frac{1}{s}K_I + sK_D \right),$$

where  $\tau > 0$  is a (fixed) time constant. Here we have an ideal PID controller, with a second-order high frequency roll-off.

**Unstable plants.** The method can be extended to handle unstable plants, but in this case the initial controller must be stabilizing and also satisfy the constraints; see, *e.g.*, [HÅBB13] for an example. (To satisfy the constraints, they can initially be relaxed.) When initialized this way, all iterates (and the final controller design) will be stabilizing.

**More outputs than actuators.** We can handle the case when  $p > m$  (more outputs than actuators), so perfect static tracking cannot be achieved. In this case we cannot have zero sensitivity at  $s = 0$ , but we can optimize over the value of  $S(0)$ , for example, minimize or limit its norm.

**Convex constraints on controller parameters.** Any convex constraints on the controller parameters can be imposed. For example, we can limit the values of any of the coefficients. A very interesting option here is to limit the sparsity pattern of  $C$  by requiring some entries to be zero. This gives structured MIMO PID controller design [Sae06].

The simple initialization method described in §6.1 will generally not work when the controller parameters are constrained, for example, when a specific sparsity pattern is imposed.

**Convex cost terms.** We can add any convex function of the controller parameters to the objective. For example we can add regularization to the objective, *i.e.*, a function that encourages the controller parameters to be small. The classical example is the sum of squares term

$$\lambda \sum_{ij} ((K_P)_{ij}^2 + (K_I)_{ij}^2 + (K_D)_{ij}^2),$$

where  $\lambda > 0$  is a parameter used to trade off low-frequency rejection and the size of the controller parameters (measured by the sum of squares).

A very interesting regularization is one that encourages sparsity in the controller parameters, such as

$$\lambda \sum_{ij} \max\{(K_P)_{ij}, (K_I)_{ij}, (K_D)_{ij}\}.$$

This regularization will encourage sparsity in  $C(s)$ ; for similar work, see, *e.g.*, [LFJ12] (for sparse controller design) and [ZH05] (for sparsity of blocks of regressors in statistics).

**Closed-loop convex constraints.** We can also add any constraint or objective term that is convex in the closed-loop transfer functions; see the book [BB91]. For example, we could include time-domain constraints such as a maximum step response settling time. The very same method (with some added terms to handle the added constraints) will work.

**Robustness to plant variations.** We can wrap robustness to plant variations into the method. A particularly simple (but very effective) method that gives robustness is to require that the constraints hold not just for one plant, but for several or many plausible values of the plant transfer function. This leads to a bigger problem to solve, but the same method works.

**More general controllers.** Finally, it should be clear that the method works for any linearly parametrized controller, and not just the simple PID structure that we have focussed on here. For more general structures the design initialization can become a challenge, however.

## 8 Examples

In this section we describe numerical results for a classic MIMO plant, the 2-input 2-output Wood-Berry binary distillation column described in [WB73]. The computations were carried out using CVX [Res12, GB08].

The plant transfer function is

$$P(s) = \begin{bmatrix} \frac{12.8e^{-s}}{16.7s + 1} & \frac{-18.9e^{-3s}}{21.0s + 1} \\ \frac{6.6e^{-7s}}{10.9s + 1} & \frac{-19.4e^{-3s}}{14.2 + 1} \end{bmatrix}.$$

Each entry is a first order system with a time delay. The dynamics are quite coupled, so finding a good MIMO PID controller is not simple. Several design methods and actual designs for this plant have been proposed in the literature, including [DB97, WZLB97, TCM02]. Our method produced quite similar results, with the same or better metrics judged by our objectives (naturally).

We used design parameters

$$S_{\max} = 1.4, \quad T_{\max} = 1.4, \quad Q_{\max} = 3/\sigma_{\min}(P(0)) = 0.738.$$

The derivative action time constant is chosen to be  $\tau = 0.3$ . The semi-infinite constraints are sampled using  $N = 300$  logarithmically spaced frequency samples in the interval  $[10^{-3}, 10^3]$ . The initial design uses the method described in §6.1 with  $\epsilon = 0.01$ .

The algorithm converges in 7 iterations (which takes a few minutes to run in our simple implementation) to the values

$$K_P = \begin{bmatrix} 0.1750 & -0.0470 \\ -0.0751 & -0.0709 \end{bmatrix}, \quad K_I = \begin{bmatrix} 0.0913 & -0.0345 \\ 0.0402 & -0.0328 \end{bmatrix}, \quad K_D = \begin{bmatrix} 0.1601 & -0.0051 \\ 0.0201 & -0.1768 \end{bmatrix},$$




Figure 3: Closed-loop transfer function singular values versus frequency, with constraints shown in red.

which achieves objective value  $\|(P(0)K_I)^{-1}\| = 2.25$ . The resulting closed-loop transfer function singular values are plotted versus frequency in figure 3, along with the imposed limits.

To demonstrate one simple extension, we also carry out MIMO PID design with the additional constraint that the controller is diagonal, *i.e.*, consists of two SISO PID loops. We initialize the algorithm with low gain PI control from  $y_1$  to  $u_1$  and from  $y_2$  to  $u_2$ , using the (diagonal) controller

$$K_P = 10^{-3} \begin{bmatrix} 1 & 0 \\ 0 & -1 \end{bmatrix}, \quad K_I = 10^{-3} \begin{bmatrix} 1 & 0 \\ 0 & -1 \end{bmatrix}, \quad K_D = 0.$$

(The minus sign in the 2,2 entry is due to the negative 2,2 value of the 2,2 entry of  $P(0)$ .) The algorithm converges in 8 iterations (taking a few minutes in our simple implementation) to the controller

$$K_P = \begin{bmatrix} 0.1535 & 0 \\ 0 & -0.0692 \end{bmatrix}, \quad K_I = \begin{bmatrix} 0.0210 & 0 \\ 0 & -0.0136 \end{bmatrix}, \quad K_D = \begin{bmatrix} 0.1714 & 0 \\ 0 & -0.1725 \end{bmatrix},$$




Figure 4: Closed-loop transfer function singular values versus frequency, with constraints shown in red, for diagonal PID design.

which achieves objective value  $\|(P(0)K_I)^{-1}\| = 13.36$ , considerably worse than the objective value obtained with a general MIMO PID controller. The resulting closed-loop transfer function singular values are plotted in figure 4. We can see that low frequency sensitivity is considerably worse than that achieved by the full MIMO controller, for example by noting the value of  $\|S(\omega)\|_2$  for  $\omega = 10^{-2}$ .

The step responses of  $T$ , the transfer function from  $r$  to  $y$ , are plotted in figure 5, for both the full MIMO PID controller and the diagonal PID controller. Here too we can observe the worse low frequency rejection for the diagonal PID design, for example in the larger off-diagonal entries of the step response. The step responses of  $Q$ , the transfer function from  $r$  to  $u$ , are plotted in figure 6, for both the full MIMO PID controller and the diagonal PID controller.




Figure 5: Closed-loop step response from  $r$  to  $y$  for the MIMO PID controller (blue) and the diagonal PID controller (red).






Figure 6: Closed-loop step response from  $r$  to  $u$  for the MIMO PID controller (blue) and the diagonal PID controller (red).

## 9 Conclusions

In this paper we have described a simple method for effectively designing MIMO PID controllers for stable plants given by transfer function (at an appropriate set of frequencies). The method relies on solving a short sequence of SDPs (typically 10 or fewer), and although it cannot guarantee finding the globally optimal design, it appears to find very good designs in practical problems. The method is related to several other methods for MIMO PID design, and relies on ideas that have been used in several other contexts in optimization, such as the convex-concave procedure, and iterative convex restriction.

## References

- [ÅH06] K. J. Åström and T. Häggglund. *Advanced PID Control*. Instrumentation, Systems, and Automation Society, 2006.
- [ÅPH98] K. J. Åström, H. Panagopoulos, and T. Häggglund. Design of PI controllers based on non-convex optimization. *Automatica*, 34(5):585–601, 1998.
- [BB91] S. Boyd and C. Barratt. *Linear Controller Design — Limits of Performance*. Prentice-Hall, 1991.
- [BGFB94] S. Boyd, L. El Ghaoui, E. Feron, and V. Balakrishnan. *Linear Matrix Inequalities in System and Control Theory*, volume 15 of *Studies in Applied Mathematics*. SIAM, 1994.
- [BMC08] F. D. Bianchi, R. D. Mantz, and C. F. Christiansen. Multivariable PID control with set-point weighting via BMI optimisation. *Automatica*, 44(2):472–478, 2008.
- [BV04] S. Boyd and L. Vandenberghe. *Convex Optimization*. Cambridge University Press, 2004.
- [DB97] J. Dong and C. Brosilow. Design of robust multivariable PID controllers via IMC. In *Proceedings of the American Control Conference*, volume 5, pages 3380–3384, 1997.
- [GB08] M. Grant and S. Boyd. Graph implementations for nonsmooth convex programs. In V. Blondel, S. Boyd, and H. Kimura, editors, *Recent Advances in Learning and Control*, Lecture Notes in Control and Information Sciences, pages 95–110. Springer-Verlag Limited, 2008.
- [GH08] O. Garpinger and T. Häggglund. A software tool for robust PID design. In *Proceedings 17th IFAC World Congress*, 2008.
- [GHÅ12] O. Garpinger, T. Häggglund, and K. J. Åström. Criteria and trade-offs in PID design. In *IFAC Conference on Advances in PID Control*, Brescia, Italy, March 2012.
- [HÅBB13] M. Hast, K. Åström, B. Bernhardsson, and S. Boyd. PID design by convex-concave optimization. In *Proceedings European Control Conference*, pages 4460–4465, July 2013.
- [LB14] T. Lipp and S. Boyd. Extensions and variations on the convex-concave procedure, 2014.
- [LFJ12] F. Lin, M. Fardad, and M. Jovanovic. Sparse feedback synthesis via the alternating direction method of multipliers. In *Proceedings of the American Control Conference*, pages 4765–4770, 2012.

- [Luy86] W. L. Luyben. Simple method for tuning SISO controllers in multivariable systems. *Industrial & Engineering Chemistry Process Design and Development*, 25(3):654–660, 1986.
- [LWL04] C. Lin, Q. G. Wang, and T. H. Lee. An improvement on multivariable PID controller design via iterative LMI approach. *Automatica*, 40(3):519–525, 2004.
- [OR70] R. Ortega and W. Rheinboldt. *Iterative Solutions of Nonlinear Equations in Several Variables*. Academic Press, 1970.
- [PÅH02] H. Panagopoulos, K. J. Åström, and T. Hägglund. Design of PID controllers based on constrained optimisation. In *IEE Proceedings on Control Theory and Applications*, volume 149, pages 32–40, 2002.
- [PK80] J. Penttinen and H. N. Koivo. Multivariable tuning regulators for unknown systems. *Automatica*, 16(4):393–398, 1980.
- [Res12] CVX Research. CVX: Matlab software for disciplined convex programming, version 2.0. <http://cvxr.com/cvx>, August 2012.
- [Sae06] M. Saeki. Fixed structure PID controller design for standard  $H_\infty$  control problem. *Automatica*, 42(1):93–100, 2006.
- [SKW07] M. Saeki, K. Kashiwagi, and N. Wada. Design of multivariable  $H_\infty$  PID controller using frequency response. In *Proc. of the 2007 IEEE Int. Conf. on Control Applications*, pages 1565–1570, oct 2007.
- [SOW10] M. Saeki, M. Ogawa, and N. Wada. Low-order  $H_\infty$  controller design on the frequency domain by partial optimization. *International Journal of Robust and Nonlinear Control*, 20:323–333, 2010.
- [TCM02] W. Tan, T. Chen, and H. Marquez. Robust controller design and PID tuning for multivariable processes. *Asian Journal of control*, 4(4):439–451, 2002.
- [VB96] L. Vandenberghe and S. Boyd. Semidefinite programming. *SIAM Review*, 38(1):49–95, March 1996.
- [VV12] R. Vilanova and A. Visioli. *PID Control in the Third Millennium: Lessons Learned and New Approaches*. Springer Verlag, 2012.
- [WB73] R. Wood and M. Berry. Terminal composition control of a binary distillation column. *Chemical Engineering Science*, 28(9):1707–1717, 1973.
- [WZLB97] Q. Wang, B. Zou, T. Lee, and Q. Bi. Auto-tuning of multivariable PID controllers from decentralized relay feedback. *Automatica*, 33(3):319–330, 1997.
- [YR03] A. Yuille and A. Rangarajan. The concave-convex procedure. *Neural Computation*, 15(4):915–936, 2003.

- [ZH05] H. Zou and T. Hastie. Regularization and variable selection via the elastic net. 67(2):301–320, 2005.